



9399 West Higgins Road Suite 1100
Rosemont, IL 60018

Phone: 847 430 1219
Fax: 847 430 2219

IBWA STANDARD OF QUALITY REPORT

Customer Name: Southeast Texas Water
Customer Address:
Customer City, State:

Page 1 of 15

Sample Date: 5/23/2016
Sample Description: Drinking
Date Reviewed: 7/5/2016

Sample I.D. 1612366
Report Date 7/5/2016

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7440-36-0	Antimony	<2.00	6.00	2.00	ug/L	200.8
7440-39-3	Barium	<10.00	1,000.00	10.00	ug/L	200.7 Rev. 4.4
7940-41-7	Beryllium	<0.10	4.00	0.10	ug/L	200.8
	Bromate (BrO3)	<2.50	10.00	2.50	ug/L	321.8 Rev. 1
7440-43-9	Cadmium (Cd)	<0.10	5.00	0.10	ug/L	200.8
	Chloramine	<0.02	4.00	0.02	mg/L	330.5
	Chlorine Dioxide	0.00	0.80		mg/L	STND 4500
	Chlorine, Free	0.00	0.10		mg/L	330.5
	Chlorine, Total	0.00	0.10		mg/L	330.5
	Chlorite (ClO2)	ND	1.00		mg/L	
7440-47-3	Chromium	<0.50	50.00	0.50	ug/L	200.8
16984-48-8	Fluoride	<0.20	3.00	0.20	mg/L	300.0
7439-92-1	Lead (Pb)	<1.00	5.00	1.00	ug/L	200.8
7439-97-6	Mercury (Hg)	<0.20	1.00	0.20	ug/L	245.1 Rev. 3
7440-02-0	Nickel (Ni)	<10.00	100.00	10.00	ug/L	200.7 Rev. 4.4
14797-55-8	Nitrate as N	<0.20	10.00	0.20	mg/L	300.0
14797-65-0	Nitrite as N	<0.10	1.00	0.10	mg/L	300.0
	Perchlorate	<0.20	2.00	0.20	ug/L	314.0
7782-49-2	Selenium (Se)	<2.00	10.00	2.00	ug/L	200.8
7440-28-0	Thallium (Tl)	<1.00	2.00	1.00	ug/L	200.8
7440-38-2	Total Arsenic	<1.00	10.00	1.00	ug/L	200.8
	Total Chlorine	0.00			mg/L	330.5

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT

Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7429-90-5	Aluminum	<2.00	200.00	2.00	ug/L	200.8
	Chloride	<0.50	250.00	0.50	mg/L	300.0
7440-50-8	Copper (Cu)	<0.00	1.00	0.00	mg/L	200.8
	Est TDS By Conductivity	4.46	500.00		mg/L	
7439-89-6	Iron (Fe)	<0.05		0.05	mg/L	200.7 Rev. 4.4
7439-96-5	Manganese (Mn)	<0.02	0.05	0.02	mg/L	200.7 Rev. 4.4
7440-22-4	Silver (Ag)	<0.10	25.00	0.10	ug/L	200.8
14808-79-8	Sulfate	<3.00	250.00	3.00	mg/L	300.0
7440-66-6	Zinc (Zn)	<0.05	5.00	0.05	mg/L	200.7 Rev. 4.4

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
75-34-3	1,1 Dichloroethane	<1.00		1.00	ug/L	524
75-35-4	1,1 Dichloroethene	<1.00	2.00	1.00	ug/L	524
563-58-6	1,1 Dichloropropene	<1.00		1.00	ug/L	524
71-55-6	1,1,1, Trichloroethane	<1.00	30.00	1.00	ug/L	524
630-20-6	1,1,1,2 Tetrachloroethane	<1.00		1.00	ug/L	524
79-00-5	1,1,2 Trichloroethane	<1.00	3.00	1.00	ug/L	524
107-06-2	1,2 - Dichloroethane	<1.00	2.00	1.00	ug/L	524
96-12-8	1,2 Dibromo-3-chloroprop	<1.00		1.00	ug/L	524
106-93-4	1,2 Dibromoethane (EDB)	<1.00		1.00	ug/L	524
95-50-1	1,2 Dichlorobenzene	<1.00	600.00	1.00	ug/L	524
78-87-5	1,2 Dichloropropane	<1.00	5.00	1.00	ug/L	524
	1,2,3 Trichlorobenzene	<1.00		1.00	ug/L	524
96-18-4	1,2,3 Trichloropropane	<1.00		1.00	ug/L	524
120-82-1	1,2,4 Trichlorobenzene	<1.00	9.00	1.00	ug/L	524
	1,2,4 Trimethylbenzene	<1.00		1.00	ug/L	524
541-73-1	1,3 Dichlorobenzene	<1.00		1.00	ug/L	524
142-28-9	1,3 Dichloropropane	<1.00		1.00	ug/L	524
	1,3,5 Trimethylbenzene	<1.00		1.00	ug/L	524
106-46-7	1,4 Dichlorobenzene	<1.00	75.00	1.00	ug/L	524
590-20-7	2,2 Dichloropropane	<1.00		1.00	ug/L	524
95-49-8	2-Chlorotoluene	<1.00		1.00	ug/L	524
591-78-6	2-Hexanone	<1.00		1.00	ug/L	524
106-43-4	4-Chlorotoluene	<1.00		1.00	ug/L	524
67-64-1	Acetone	11.20		10.00	ug/L	524
71-43-2	Benzene	<1.00	1.00	1.00	ug/L	524
108-86-1	Bromobenzene	<1.00		1.00	ug/L	524
74-97-5	Bromochloromethane	<1.00		1.00	ug/L	524
75-27-4	Bromodichloromethane	<1.00		1.00	ug/L	524
75-25-2	Bromoform	<1.00		1.00	ug/L	524
74-83-9	Bromomethane	<1.00		1.00	ug/L	524
75-15-0	Carbon Disulfide	<1.00		1.00	ug/L	524
56-23-5	Carbon Tetrachloride	<1.00	5.00	1.00	ug/L	524
108-90-7	Chlorobenzene	<1.00	50.00	1.00	ug/L	524
75-00-3	Chloroethane	<1.00		1.00	ug/L	524
67-66-3	Chloroform	<1.00		1.00	ug/L	524
74-87-3	Chloromethane	<1.00		1.00	ug/L	524
156-59-4	Cis-1,2-Dichloroethene	<1.00	70.00	1.00	ug/L	524
10061-01-5	Cis-1,3-Dichloropropene	<1.00		1.00	ug/L	524
124-48-1	Dibromochloromethane	<1.00		1.00	ug/L	524
74-95-3	Dibromomethane	<1.00		1.00	ug/L	524
75-71-8	Dichlorodifluoromethane	<1.00		1.00	ug/L	524
75-09-2	Dichloromethane	<1.00	3.00	1.00	ug/L	524
100-41-4	Ethylbenzene	<1.00	700.00	1.00	ug/L	524
87-68-3	Hexachlorbutadiene	<1.00		1.00	ug/L	524
74-88-4	Iodomethane	<1.00		1.00	ug/L	524

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT

98-82-8	Isopropylbenzene	<1.00		1.00	ug/L	524
	m,p-Xylene	<1.00	1.00	1.00	ug/L	524
78-93-3	Methyl Ethyl Ketone	<1.00		1.00	ug/L	524
108-10-1	Methyl Isobutyl Ketone	<1.00		1.00	ug/L	524
	n-Butylbenzene	<1.00		1.00	ug/L	524
	n-Propylbenzene	<1.00		1.00	ug/L	524
95-47-6	o-Xylene	<1.00		1.00	ug/L	524
	p-iso-Propyltoluene	<1.00		1.00	ug/L	524
	sec-Butylbenzene	<1.00		1.00	ug/L	524
100-42-5	Styrene	<1.00	100.00	1.00	ug/L	524
98-06-6	Tert-Butylbenzene	<1.00		1.00	ug/L	524
127-18-4	Tetrachloroethene	<1.00	1.00	1.00	ug/L	524
108-88-3	Toluene	<1.00	1,000.00	1.00	ug/L	524
156-60-5	Trans-1,2-Dichloroethene	<1.00	100.00	1.00	ug/L	524
10061-02-6	Trans-1,3-Dichloropropen	<1.00		1.00	ug/L	524
79-01-6	Trichloroethene	<1.00	1.00	1.00	ug/L	524
75-69-4	Trichlorofluoromethane	<1.00		1.00	ug/L	524
108-05-4	Vinyl Acetate	<1.00		1.00	ug/L	524
75-01-4	Vinyl Chloride	<1.00	2.00	1.00	ug/L	524

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT

Additional Regulated Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
79-34-5	1,1,2,2 Tetrachloroethane	<1.00	1.00	1.00	ug/L	524
1634-04-4	Methyl T-Butyl Ether	<1.00	70.00	1.00	ug/L	524
91-20-3	Naphthalene	<1.00	300.00	1.00	ug/L	524
7440-61-1	Uranium (U)	<2.00	30.00	2.00	ug/L	200.8

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT

Water Properties						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	Color	<5.00	5.00	5.00		SM2120C
	Color after Acidification	<5.00	5.00	5.00		SM2120C
	Conductivity	6.30			µMHOS/CM	120.1
	pH	6.94	8.50			150.1 1982
	Turbidity	0.24	0.50	0.10	NTU	180.1 Rev. 2 1993
	Turbidity Filtered	ND	0.50		NTU	180.1 Rev. 2 1993

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT

Hardness						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7440-70-2	Calcium	<0.10		0.10	mg/L	200.7 Rev. 4.4
	Hardness (CaCO3)	0.05			mg/L	200.7 Rev. 4.4
7439-95-4	Magnesium	<0.10		0.10	mg/L	200.7 Rev. 4.4
7440-23-5	Sodium	1.32		0.10	mg/L	200.7 Rev. 4.4

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT

Uncategorized						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	Bicarbonate	2.53			mg/L	SM 2320 B Rev. 18
	Bromide (Br)	<5.00		5.00	ug/L	321.8 Rev. 1
	Carbonate	NM			mg/L	SM 2320 B Rev. 18
	Contract Lab	See Attached Report				
7440-09-7	Potassium	0.32		0.10	mg/L	200.7 Rev. 4.4
7631-86-9	Silica	0.68		0.01	mg/L	200.7 Rev. 4.4
7440-24-6	Strontium (Sr)	<0.05		0.05	mg/L	200.7 Rev. 4.4
	Tannins	<2.00		2.00	mg/L	SM 5550

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT



1612366

Control Number:

SAMPLE ANALYSIS REQUEST
 Pace Analytical
 Attn: Sample Receiving
 8 East Tower Circle
 Ormond Beach, FL 32174

SAMPLE SUBMITTED BY:			
Account Number:	42-065		
Account Name:	Southeast Texas Water		
Phone Number:	409-833-6200		
E-MAIL:	matthew@setxwater.com		
Person Taking Sample:	matt Gilby		
Date Sample Taken:	5/23/16	Time Sample Taken:	8 AM
CUSTOMER INFORMATION:			
Customer Name:			
Address:			
City:	State:	Zip:	
Customer reported concern:			
SAMPLE INFORMATION:			
Water Supply:	Private <input type="checkbox"/>	Municipal <input checked="" type="checkbox"/>	
Source:	Surface <input type="checkbox"/>	Well <input checked="" type="checkbox"/>	Unknown <input type="checkbox"/>
Condition:	Treated <input checked="" type="checkbox"/>	Untreated <input type="checkbox"/>	Cloudy <input type="checkbox"/>
	Colored <input type="checkbox"/>		
Water Type:	Drinking		
ANALYSIS REQUESTED:			
IBWA Annual Testing - for Culligan International			

For Questions contact Maria Mozden at (847) 430-1219

LAB USE ONLY:			
Sample received in acceptable condition:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
Received by:	Date: 5-25-16	Time: 11:10	
If not reason:			
Disposition of sample:			

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL
 N.M. - Indicates that the compound was not measured.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.
 MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT



Pace Analytical Services, Inc.
 8 East Tower Circle
 Ormond Beach, FL 32174
 (386)672-6668

ANALYTICAL RESULTS

Project: Culligan DW 1612366
 Pace Project No.: 35246431

Sample: 1612366 Lab ID: 35246431001 Collected: 05/26/16 12:52 Received: 06/26/16 12:52 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
504.1 GCS EDB and DBCP Analytical Method: EPA 504.1 Preparation Method: EPA 504.1									
1,2-Dibromo-3-chloropropane	<0.0052	ug/L	0.021	0.0052	1	06/01/16 05:37	06/02/16 17:57	96-12-8	
1,2-Dibromoethane (EDB)	<0.0080	ug/L	0.011	0.0080	1	06/01/16 05:37	06/02/16 17:57	106-93-4	
508.1 GCS Pesticides Analytical Method: EPA 508.1 Preparation Method: EPA 508.1									
Alachlor	<0.033	ug/L	0.19	0.033	1	06/08/16 10:00	06/14/16 00:01	15972-60-8	
Atrazine	<0.060	ug/L	0.096	0.060	1	06/08/16 10:00	06/14/16 00:01	1912-24-9	
gamma-BHC (Lindane)	<0.0029	ug/L	0.019	0.0029	1	06/08/16 10:00	06/14/16 00:01	58-89-9	
Chlordane (Technical)	<0.045	ug/L	0.19	0.045	1	06/08/16 10:00	06/14/16 00:01	57-74-9	
Endrin	<0.0067	ug/L	0.0096	0.0067	1	06/08/16 10:00	06/14/16 00:01	72-20-8	
Heptachlor	<0.011	ug/L	0.038	0.011	1	06/08/16 10:00	06/14/16 00:01	76-44-8	
Heptachlor epoxide	<0.0029	ug/L	0.019	0.0029	1	06/08/16 10:00	06/14/16 00:01	1024-57-3	
Hexachlorobenzene	<0.018	ug/L	0.096	0.018	1	06/08/16 10:00	06/14/16 00:01	118-74-1	
Hexachlorocyclopentadiene	<0.031	ug/L	0.096	0.031	1	06/08/16 10:00	06/14/16 00:01	77-47-4	
Methoxychlor	<0.049	ug/L	0.096	0.049	1	06/08/16 10:00	06/14/16 00:01	72-43-5	
PCB-1016 (Aroclor 1016)	<0.077	ug/L	0.096	0.077	1	06/08/16 10:00	06/14/16 00:01	12674-11-2	
PCB-1221 (Aroclor 1221)	<0.028	ug/L	0.096	0.028	1	06/08/16 10:00	06/14/16 00:01	11104-28-2	
PCB-1232 (Aroclor 1232)	<0.028	ug/L	0.096	0.028	1	06/08/16 10:00	06/14/16 00:01	11141-16-5	
PCB-1242 (Aroclor 1242)	<0.049	ug/L	0.096	0.049	1	06/08/16 10:00	06/14/16 00:01	53469-21-9	
PCB-1248 (Aroclor 1248)	<0.059	ug/L	0.096	0.059	1	06/08/16 10:00	06/14/16 00:01	12672-29-6	
PCB-1254 (Aroclor 1254)	<0.022	ug/L	0.096	0.022	1	06/08/16 10:00	06/14/16 00:01	11097-69-1	
PCB-1260 (Aroclor 1260)	<0.063	ug/L	0.096	0.063	1	06/08/16 10:00	06/14/16 00:01	11096-82-5	
PCB, Total	<0.077	ug/L	0.096	0.077	1	06/08/16 10:00	06/14/16 00:01	1336-36-3	
Simazine	<0.066	ug/L	0.067	0.066	1	06/08/16 10:00	06/14/16 00:01	122-34-9	
Toxaphene	<0.58	ug/L	0.96	0.58	1	06/08/16 10:00	06/14/16 00:01	8001-35-2	
Surrogates									
Decachlorobiphenyl (S)	63	%	70-130		1	06/08/16 10:00	06/14/16 00:01	2051-24-3	1p,S7
515.3 Chlorinated Herbicides Analytical Method: EPA 515.3 Preparation Method: EPA 515.3									
2,4-D	<0.081	ug/L	0.10	0.081	1	06/02/16 08:15	06/04/16 06:35	94-75-7	
Dalapon	<0.89	ug/L	1.0	0.89	1	06/02/16 08:15	06/04/16 06:35	75-99-0	
Dinoseb	<0.16	ug/L	0.20	0.16	1	06/02/16 08:15	06/04/16 06:35	88-85-7	
Pentachlorophenol	<0.030	ug/L	0.040	0.030	1	06/02/16 08:15	06/04/16 06:35	87-86-5	
Picloram	<0.094	ug/L	0.10	0.094	1	06/02/16 08:15	06/04/16 06:35	1918-02-1	
2,4,5-TP (Silvex)	<0.16	ug/L	0.20	0.16	1	06/02/16 08:15	06/04/16 06:35	93-72-1	
Surrogates									
2,4-DCAA (S)	93	%	70-130		1	06/02/16 08:15	06/04/16 06:35	19719-28-9	
531.1 HPLC Carbamates Analytical Method: EPA 531.1									
Aldicarb	<0.64	ug/L	2.0	0.64	1		05/29/16 22:22	116-06-3	
Aldicarb sulfone	<0.37	ug/L	2.0	0.37	1		05/29/16 22:22	1646-88-4	
Aldicarb sulfoxide	<0.30	ug/L	2.0	0.30	1		05/29/16 22:22	1646-87-3	
Carbofuran	<0.32	ug/L	2.0	0.32	1		05/29/16 22:22	1563-66-2	
Oxamyl	<0.55	ug/L	2.0	0.55	1		05/29/16 22:22	23135-22-0	
Surrogates									
BDMC (S)	110	%	80-120		1		05/29/16 22:22		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, Inc.

Date: 07/05/2016 12:18 PM

Page 5 of 47

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200

Maria Mozden
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT



Pace Analytical Services, Inc.
8 East Tower Circle
Ormond Beach, FL 32174
(386)672-5668

ANALYTICAL RESULTS

Project: Culligan DW 1612366
Pace Project No.: 35246431

Sample: 1612366 Lab ID: 35246431001 Collected: 05/26/16 12:52 Received: 05/26/16 12:52 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
547 HPLC Glyphosate Analytical Method: EPA 547									
Glyphosate	<0.37	ug/L	6.0	2.8	1		06/01/16 17:16		L3
549.2 HPLC Paraquat Diquat Analytical Method: EPA 549.2 Preparation Method: EPA 549.2									
Diquat	<0.30	ug/L	0.40	0.30	1	05/31/16 23:45	06/02/16 06:46	85-00-7	
552.2 Haloacetic Acids Analytical Method: EPA 552.2 Preparation Method: EPA 552.2									
Dibromoacetic Acid	<0.37	ug/L	1.0	0.37	1	06/02/16 11:20	06/04/16 09:08	631-64-1	
Dichloroacetic Acid	<0.37	ug/L	1.0	0.37	1	06/02/16 11:20	06/04/16 09:08	79-43-6	
Haloacetic Acids (Total)	<0.37	ug/L	1.0	0.37	1	06/02/16 11:20	06/04/16 09:08		
Monobromoacetic Acid	<0.37	ug/L	1.0	0.37	1	06/02/16 11:20	06/04/16 09:08	79-08-3	
Monochloroacetic Acid	<0.37	ug/L	1.0	0.37	1	06/02/16 11:20	06/04/16 09:08	79-11-8	
Trichloroacetic Acid	<0.37	ug/L	1.0	0.37	1	06/02/16 11:20	06/04/16 09:08	76-03-9	
Surrogates									
2,3-Dibromopropanoic Acid (S)	103	%	70-130		1	06/02/16 11:20	06/04/16 09:08	600-05-5	
525.2 Base Neutral Extractable Analytical Method: EPA 525.2 Preparation Method: EPA 525.2									
Benzo(a)pyrene	<0.012	ug/L	0.096	0.012	1	06/08/16 10:00	06/09/16 12:04	50-32-8	
bis(2-Ethylhexyl)adipate	<0.37	ug/L	1.5	0.37	1	06/08/16 10:00	06/09/16 12:04	103-23-1	
bis(2-Ethylhexyl)phthalate	<0.53	ug/L	1.9	0.53	1	06/08/16 10:00	06/09/16 12:04	117-81-7	
Surrogates									
1,3-Dimethyl-2-nitrobenzene(S)	107	%	70-130		1	06/08/16 10:00	06/09/16 12:04	81209	
Perylene-d12 (S)	97	%	70-130		1	06/08/16 10:00	06/09/16 12:04	1520963	
Triphenylphosphate (S)	137	%	70-130		1	06/08/16 10:00	06/09/16 12:04	115-86-6	S3
548.1 GCS Endothall Analytical Method: EPA 548.1 Preparation Method: EPA 548.1									
Endothall	<4.3	ug/L	9.0	4.3	1	06/02/16 08:00	06/03/16 04:50		
300.1 Oxihalide IC Anions 14d Analytical Method: EPA 300.1									
Chlorite	<1.4	ug/L	5.0	1.4	1		05/30/16 03:26		
Surrogates									
Dichloroacetate (S)	107	%	90-115		1		05/30/16 03:26	79-43-6	
335.4 Cyanide, Total Analytical Method: EPA 335.4 Preparation Method: EPA 335.4									
Cyanide	<0.0050	mg/L	0.010	0.0050	1	06/07/16 01:40	06/07/16 15:56	57-12-5	M1
353.2 Nitrogen, NO2/NO3 unpres Analytical Method: EPA 353.2									
Nitrogen, Nitrate	0.031J	mg/L	0.050	0.025	1		05/27/16 16:23		
Nitrogen, Nitrite	<0.025	mg/L	0.050	0.025	1		05/27/16 16:23		
Nitrogen, NO2 plus NO3	0.031J	mg/L	0.050	0.025	1		05/27/16 16:23		
420.4 Phenolics, Total Low Lvl Analytical Method: EPA 420.4 Preparation Method: EPA 420.4									
Phenolics, Total Recoverable LL	<0.0010	mg/L	0.0010	0.0010	1	06/06/16 09:00	06/06/16 17:29		N2

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, Inc..

Date: 07/05/2016 12:18 PM

Page 6 of 47

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL
N.M. - Indicates that the compound was not measured.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.
MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT



Pace Analytical Services, Inc.
 8 East Tower Circle
 Ormond Beach, FL 32174
 (386)672-5668

ANALYTICAL RESULTS

Project: Culligan DW 1612366
 Pace Project No.: 35246431

Sample: 1612366 Lab ID: 35246431002 Collected: 05/26/16 12:52 Received: 05/26/16 12:52 Matrix: Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
Analytical Method: EPA 8260									
8260 MSV									
Acetone	11.2J	ug/L	20.0	10.0	1		06/01/16 13:44	67-64-1	
Acetonitrile	<5.0	ug/L	10.0	5.0	1		06/01/16 13:44	75-05-8	
Benzene	<0.10	ug/L	1.0	0.10	1		06/01/16 13:44	71-43-2	
Bromochloromethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	74-97-5	
Bromodichloromethane	<0.27	ug/L	0.60	0.27	1		06/01/16 13:44	75-27-4	
Bromoform	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	75-25-2	
Bromomethane	<0.50	ug/L	5.0	0.50	1		06/01/16 13:44	74-83-9	
2-Butanone (MEK)	<5.0	ug/L	10.0	5.0	1		06/01/16 13:44	78-93-3	
Carbon disulfide	<5.0	ug/L	10.0	5.0	1		06/01/16 13:44	75-15-0	
Carbon tetrachloride	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	56-23-5	
Chlorobenzene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	108-90-7	
Chloroethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	75-00-3	
Chloroform	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	67-66-3	
Chloromethane	<0.62	ug/L	1.0	0.62	1		06/01/16 13:44	74-87-3	
1,2-Dibromo-3-chloropropane	<1.0	ug/L	2.0	1.0	1		06/01/16 13:44	96-12-8	
Dibromochloromethane	<0.26	ug/L	0.50	0.26	1		06/01/16 13:44	124-48-1	
1,2-Dibromoethane (EDB)	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	106-93-4	
Dibromomethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	74-95-3	
1,2-Dichlorobenzene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	95-50-1	
1,4-Dichlorobenzene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	106-46-7	
trans-1,4-Dichloro-2-butene	<5.0	ug/L	10.0	5.0	1		06/01/16 13:44	110-57-6	
1,1-Dichloroethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	75-34-3	
1,2-Dichloroethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	107-06-2	
1,2-Dichloroethane (Total)	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	540-59-0	N2
1,1-Dichloroethene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	75-35-4	
cis-1,2-Dichloroethene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	156-59-2	
trans-1,2-Dichloroethene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	156-60-5	
1,2-Dichloropropane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	78-87-5	
cis-1,3-Dichloropropene	<0.25	ug/L	0.50	0.25	1		06/01/16 13:44	10061-01-5	
trans-1,3-Dichloropropene	<0.25	ug/L	0.50	0.25	1		06/01/16 13:44	10061-02-6	
Ethylbenzene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	100-41-4	
2-Hexanone	<5.0	ug/L	10.0	5.0	1		06/01/16 13:44	591-78-6	
Iodomethane	<0.50	ug/L	10.0	0.50	1		06/01/16 13:44	74-88-4	
Isopropylbenzene (Cumene)	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	98-82-8	
Methylene Chloride	<2.5	ug/L	5.0	2.5	1		06/01/16 13:44	75-09-2	
4-Methyl-2-pentanone (MIBK)	<5.0	ug/L	10.0	5.0	1		06/01/16 13:44	108-10-1	
Methyl-tert-butyl ether	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	1634-04-4	
Styrene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	100-42-5	
1,1,1,2-Tetrachloroethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	630-20-6	
1,1,2,2-Tetrachloroethane	<0.12	ug/L	0.50	0.12	1		06/01/16 13:44	79-34-5	
Tetrachloroethene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	127-18-4	
Toluene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	108-88-3	
1,1,1-Trichloroethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	71-55-6	
1,1,2-Trichloroethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	79-00-5	
Trichloroethene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	79-01-6	
Trichlorofluoromethane	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	75-69-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, Inc..

Date: 07/05/2016 12:18 PM

Page 7 of 47

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200

Maria Mozden
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT



Pace Analytical Services, Inc.
 8 East Tower Circle
 Ormond Beach, FL 32174
 (386)672-5668

ANALYTICAL RESULTS

Project: Culligan DW 1612366
 Pace Project No.: 35246431

Sample: 1612366 Lab ID: 35246431002 Collected: 05/26/16 12:52 Received: 05/26/16 12:52 Matrix: Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
8260 MSV									
Analytical Method: EPA 8260									
1,2,3-Trichloropropane	<0.59	ug/L	1.0	0.59	1		06/01/16 13:44	96-18-4	
1,2,4-Trimethylbenzene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	95-63-6	
1,3,5-Trimethylbenzene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	108-67-8	
Vinyl acetate	<1.0	ug/L	2.0	1.0	1		06/01/16 13:44	108-05-4	
Vinyl chloride	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	75-01-4	
Xylene (Total)	<1.5	ug/L	3.0	1.5	1		06/01/16 13:44	1330-20-7	
m&p-Xylene	<1.0	ug/L	2.0	1.0	1		06/01/16 13:44	179601-23-1	
o-Xylene	<0.50	ug/L	1.0	0.50	1		06/01/16 13:44	95-47-6	
Surrogates									
4-Bromofluorobenzene (S)	99	%	70-114		1		06/01/16 13:44	460-00-4	
1,2-Dichloroethane-d4 (S)	99	%	86-125		1		06/01/16 13:44	17060-07-0	
Toluene-d8 (S)	103	%	87-113		1		06/01/16 13:44	2037-26-5	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, Inc..

Date: 07/05/2016 12:18 PM

Page 8 of 47

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.

MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT



Pace Analytical Services, Inc.
 8 East Tower Circle
 Ormond Beach, FL 32174
 (386)672-5668

ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Culligan DW 1612366
 Pace Project No.: 35246431

Sample: 1612366 Lab ID: 35246431001 Collected: 05/26/16 12:52 Received: 05/26/16 12:52 Matrix: Drinking Water
 PWS: Site ID: Sample Type:

Parameters	Method	Act ± Unc (MDC) Carr Trac	Units	Analyzed	CAS No.	Qual
Gross Alpha	EPA 900.0	1.11U ± 0.606 (1.11) C:NA T:NA	pCi/L	06/06/16 07:31	12587-46-1	
Radium-226	EPA 903.1	0.970U ± 0.477 (0.970) C:NA T:68%	pCi/L	06/13/16 10:01	13982-63-3	
Radium-228	EPA 904.0	0.969U ± 0.448 (0.969) C:79% T:73%	pCi/L	06/07/16 16:25	15262-20-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, Inc..

Page 32 of 47

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL
 N.M. - Indicates that the compound was not measured.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
 MRL - Method Reporting Limit.

IBWA STANDARD OF QUALITY REPORT



Pace Analytical Services, Inc.
1700 Elm Street - Suite 200
Minneapolis, MN 55414

Drinking Water Analysis Results
2,3,7,8-TCDD -- USEPA Method 1613B

Tel: 612-607-1700
Fax: 612-607-6444

Sample ID.....1612366 Date Collected.....05/26/2016
Client.....PASI Florida Date Received.....05/27/2016
Lab Sample ID.....35246431001 Date Extracted.....06/06/2016

	Sample 1612366	Method Blank	Lab Spike	Lab Spike Dup
[2,3,7,8-TCDD]	ND	ND	--	--
EDL	1.1 pg/L	0.30 pg/L	--	--
2,3,7,8-TCDD Recovery	--	--	97%	96%
Spike Recovery Limit	--	--	73-146%	73-146%
RPD				0.7%
IS Recovery	62%	77%	70%	72%
IS Recovery Limits	31-137%	31-137%	25-141%	25-141%
CS Recovery	84%	111%	90%	96%
CS Recovery Limits	42-164%	42-164%	37-158%	37-158%
Filename	Y160607A_04	Y160606B_11	Y160606B_09	Y160606B_10
Analysis Date	06/07/2016	06/07/2016	06/07/2016	06/07/2016
Analysis Time	18:15	10:02	09:06	09:34
Analyst	SMT	BAL	BAL	BAL
Volume	1.028L	1.018L	1.022L	1.013L
Dilution	NA	NA	NA	NA
ICAL Date	05/04/2016	05/04/2016	05/04/2016	05/04/2016
CCAL Filename	Y160607A_02	Y160606B_02	Y160606B_02	Y160606B_02

- ! = Outside the Control Limits
- ND = Not Detected
- EDL = Estimated Detection Limit
- Limits = Control Limits from Method 1613 (10/94 Revision), Tables 6A and 7A
- RPD = Relative Percent Difference of Lab Spike Recoveries
- IS = Internal Standard [2,3,7,8-TCDD-¹³C₁₂]
- CS = Cleanup Standard [2,3,7,8-TCDD-³⁷Cl₄]

Analyst:

Project No.....10350161
Page 47 of 47

Report No.....10350161_1613DW

Page 6 of 6

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL
N.M. - Indicates that the compound was not measured.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.
MRL - Method Reporting Limit.