



9399 West Higgins Road Suite 1100
Rosemont, IL 60018

Phone: 847 430 1219
Fax: 847 430 2219

IBWA STANDARD OF QUALITY REPORT

Customer Name: Southeast Texas Water
Customer Address:
Customer City, State: ,
Sample Date: 3/17/2017
Sample Description: Purified
Date Reviewed: 4/17/2017

Page 1 of 12

Sample I.D. 1705451
Report Date 4/17/2017

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7440-36-0	Antimony	ND	6.00	2.00	ug/L	200.8
7440-39-3	Barium	ND	1,000.00	10.00	ug/L	200.7 Rev. 4.4
7940-41-7	Beryllium	ND	4.00	0.10	ug/L	200.8
	Bromate (BrO3)	ND	10.00	2.50	ug/L	321.8 Rev. 1
7440-43-9	Cadmium (Cd)	ND	5.00	0.10	ug/L	200.8
	Chloramine	ND	4.00	0.02	mg/L	330.5
	Chlorine Dioxide	0.00	0.80		mg/L	STND 4500
	Chlorine, Free	0.01	0.10		mg/L	330.5
	Chlorine, Total	0.01	0.10		mg/L	330.5
7440-47-3	Chromium	ND	50.00	0.50	ug/L	200.8
16984-48-8	Fluoride	ND	3.00	0.20	mg/L	300.0
7439-92-1	Lead (Pb)	ND	5.00	1.00	ug/L	200.8
7439-97-6	Mercury (Hg)	ND	1.00	0.20	ug/L	245.1 Rev. 3
7440-02-0	Nickel (Ni)	ND	100.00	10.00	ug/L	200.7 Rev. 4.4
14797-55-8	Nitrate as N	ND	10.00	0.20	mg/L	300.0
14797-65-0	Nitrite as N	ND	1.00	0.10	mg/L	300.0
	Perchlorate	ND	2.00	0.20	ug/L	314.0
7782-49-2	Selenium (Se)	ND	10.00	2.00	ug/L	200.8
7440-28-0	Thallium (Tl)	ND	2.00	1.00	ug/L	200.8
7440-38-2	Total Arsenic	ND	10.00	1.00	ug/L	200.8
	Total Chlorine	0.01			mg/L	330.5

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
CO-IL100213; MI-9988

Maria Mozdzen
Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT

Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7429-90-5	Aluminum	ND	200.00	2.00	ug/L	200.8
	Chloride	1.28	250.00	0.50	mg/L	300.0
7440-50-8	Copper (Cu)	0.01	1.00	0.00	mg/L	200.7
	Est TDS By Conductivity	9.34	500.00		mg/L	
7439-89-6	Iron (Fe)	ND		0.05	mg/L	200.7 Rev. 4.4
7439-96-5	Manganese (Mn)	ND	0.05	0.02	mg/L	200.7 Rev. 4.4
7440-22-4	Silver (Ag)	ND	25.00	0.10	ug/L	200.8
14808-79-8	Sulfate	ND	250.00	3.00	mg/L	300.0
7440-66-6	Zinc (Zn)	ND	5.00	0.05	mg/L	200.7 Rev. 4.4

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
 CO-IL100213; MI-9988

Maria Mozdzen
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT

Additional Regulated Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7440-61-1	Uranium (U)	ND	30.00	2.00	ug/L	200.8

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
CO-IL100213; MI-9988

Maria Mozden
Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT

Water Properties						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	Color	ND	5.00	5.00	color	SM2120C
	Color after Acidification	NM	5.00	5.00	color	SM2120C
	Conductivity	14.40			microS/cm	120.1
	pH	6.70	8.50			150.1 1982
	Turbidity	0.11	0.50	0.10	NTU	180.1 Rev. 2 1993
	Turbidity Filtered	NM	0.50		NTU	180.1 Rev. 2 1993

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
 CO-IL100213; MI-9988

Maria Mozden
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT

Hardness						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7440-70-2	Calcium	0.13		0.10	mg/L	200.7 Rev. 4.4
	Hardness (CaCO3)	0.66			mg/L	200.7 Rev. 4.4
7439-95-4	Magnesium	ND		0.10	mg/L	200.7 Rev. 4.4
7440-23-5	Sodium	2.58		0.10	mg/L	200.7 Rev. 4.4

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
 CO-IL100213; MI-9988

Maria Mozdzen
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT

Uncategorized						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	Bicarbonate	3.41			mg/L	SM 2320 B Rev. 18
	Bromide (Br)	ND		10.00	ug/L	321.8 Rev. 1
	Carbonate	NM			mg/L	SM 2320 B Rev. 18
	Contract Lab	See Attached Report				
7440-09-7	Potassium	0.23		0.10	mg/L	200.7 Rev. 4.4
7631-86-9	Silica	0.70		0.01	mg/L	200.7 Rev. 4.4
7440-24-6	Strontium (Sr)	ND		0.05	mg/L	200.7 Rev. 4.4
	Tannins	ND		2.00	mg/L	SM 5550

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
 CO-IL100213; MI-9988

Maria Mozdzen
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT



1705451

Control Number:

Control Num

Pace Analytical
Attn: Sample Receiving
8 East Tower Circle
Ormond Beach, FL 32174

ANALYSIS REQUEST
DATE ANALYZED
SAMPLE IDENTIFICATION
DATE SAMPLE RECEIVED
LABORATORY USE ONLY

SAMPLE SUBMITTED BY:	
Account Number:	42-005
Account Name:	Southeast Texas Water
Phone Number:	
FAX Number:	matthew@seasteasttexaswater.com
E-MAIL:	
Person Taking Sample:	Matt Gilby
Date Sample Taken:	3/17/17
Time Sample Taken:	9:00 AM
CUSTOMER INFORMATION:	
Customer Name:	
Address:	
City:	State: Zip:
Customer reported concern:	
SAMPLE INFORMATION:	
Water Supply:	Private <input type="checkbox"/> Municipal <input checked="" type="checkbox"/>
Source:	Surface <input checked="" type="checkbox"/> Well <input checked="" type="checkbox"/> Unknown <input type="checkbox"/>
Condition:	Treated <input checked="" type="checkbox"/> Untreated <input type="checkbox"/> Cloudy <input type="checkbox"/>
Colored:	<input type="checkbox"/>
Water Type:	Purified
ANALYSIS REQUESTED:	
PFOA IBWA Annual Testing - for Culligan International	

For Questions contact Maria Mozden at (847) 430-1219

LAB USE ONLY:	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Sample received in acceptable condition:	Date: <input type="text"/>	Time: <input type="text"/>
Received by:	<input type="text"/>	
If not reason:	<input type="text"/>	
Disposition of sample:	<input type="text"/>	

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL
N.M. - Indicates that the compound was not measured.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.
MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A
State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
CO-IL100213; MI-9988

Maria Mozden
Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT



1705451



Pace Analytical Services, Inc.
 8 East Tower Circle
 Ormond Beach, FL 32174
 (386) 672-5668

Client: Culligan International

Client ID: 1705451

Project ID: 1705451

Lab ID: 35303238001

Received: 03/29/2017 17:00

Pace Project No.: 35303238

Collected: 03/29/2017 17:00

Matrix: Drinking Water

Parameters	Report Limit	Results	Units	FDA Limit	Above/Below Limit	IBWA Limit	Above/Below Limit
504.1 GCS EDB and DBCP							
Analytical Method: EPA 504.1				Preparation Method: EPA 504.1			
1,2-Dibromo-3-chloropropane	0.0060	<0.0060	ug/L	0.2	Below	0.2	Below
1,2-Dibromoethane (EDB)	0.0070	<0.0070	ug/L	0.05	Below	0.05	Below
508.1 GCS Pesticides							
Analytical Method: EPA 508.1				Preparation Method: EPA 508.1			
Alachlor	0.034	<0.034	ug/L	2	Below	2	Below
Atrazine	0.061	<0.061	ug/L	3	Below	3	Below
gamma-BHC (Lindane)	0.0029	<0.0029	ug/L	0.2	Below	0.2	Below
Chlordane (Technical)	0.045	<0.045	ug/L	2	Below	2	Below
Endrin	0.0067	<0.0067	ug/L	2	Below	2	Below
Heptachlor	0.012	<0.012	ug/L	0.4	Below	0.4	Below
Heptachlor epoxide	0.0029	<0.0029	ug/L	0.2	Below	0.2	Below
Hexachlorobenzene	0.018	<0.018	ug/L	1	Below	1	Below
Hexachlorocyclopentadiene	0.031	<0.031	ug/L	50	Below	50	Below
Methoxychlor	0.049	<0.049	ug/L	40	Below	40	Below
PCB-1016 (Aroclor 1016)	0.077	<0.077	ug/L				
PCB-1221 (Aroclor 1221)	0.028	<0.028	ug/L				
PCB-1232 (Aroclor 1232)	0.028	<0.028	ug/L				
PCB-1242 (Aroclor 1242)	0.049	<0.049	ug/L				
PCB-1248 (Aroclor 1248)	0.060	<0.060	ug/L				
PCB-1254 (Aroclor 1254)	0.022	<0.022	ug/L				
PCB-1260 (Aroclor 1260)	0.063	<0.063	ug/L				
PCB, Total	0.077	<0.077	ug/L	0.5	Below	0.5	Below
Simazine	0.066	<0.066	ug/L	4	Below	4	Below
Toxaphene	0.58	<0.58	ug/L	3	Below	3	Below
515.3 Chlorinated Herbicides							
Analytical Method: EPA 515.3				Preparation Method: EPA 515.3			
2,4-D	0.081	<0.081	ug/L	70	Below	70	Below
Dalapon	0.89	<0.89	ug/L	200	Below	200	Below
Dinoseb	0.16	<0.16	ug/L	7	Below	7	Below
Pentachlorophenol	0.030	<0.030	ug/L	1	Below	1	Below
Picloram	0.094	<0.094	ug/L	500	Below	500	Below
2,4,5-TP (Silvex)	0.16	<0.16	ug/L	50	Below	10	Below
531.1 HPLC Carbamates							
Analytical Method: EPA 531.1							
Aldicarb	0.64	<0.64	ug/L			3	Below
Aldicarb sulfone	0.37	<0.37	ug/L			3	Below
Aldicarb sulfoxide	0.59	<0.59	ug/L			4	Below
Carbofuran	0.32	<0.32	ug/L				
Oxamyl	0.55	<0.55	ug/L	200	Below	200	Below
537 Perfluorinated Compounds							
Analytical Method: EPA 537				Preparation Method: EPA 537			
Perfluorobutanesulfonic acid	0.043	<0.043	ug/L				
Perfluoroheptanoic acid	0.0019	<0.0019	ug/L				
Perfluorohexanesulfonic acid	0.0058	<0.0058	ug/L				
Perfluorononanoic acid	0.0055	<0.0055	ug/L				
Perfluorooctanesulfonic acid	0.0086	<0.0086	ug/L				
Perfluorooctanoic acid	0.00057	0.00079J	ug/L				
547 HPLC Glyphosate							
Analytical Method: EPA 547							
Glyphosate	4.2	<4.2	ug/L	700	Below	700	Below
549.2 HPLC Paraquat Diquat							
Analytical Method: EPA 549.2				Preparation Method: EPA 549.2			

04/14/2017 16:08:51

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL
 N.M. - Indicates that the compound was not measured.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.
 MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A
 State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
 CO-IL100213; MI-9988

Maria Mozden
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT



Sample Results

Pace Analytical Services, Inc.
 8 East Tower Circle
 Ormond Beach, FL 32174
 (386) 672-5668

Client: Culligan International

Client ID: 1705451

Project ID: 1705451

Lab ID: 35303238001
 Collected: 03/29/2017 17:00

Received: 03/29/2017 17:00

Pace Project No.: 35303238

Matrix: Drinking Water

Parameters	Report Limit	Results	Units	FDA Limit	Above/Below Limit	IBWA Limit	Above/Below Limit
549.2 HPLC Paraquat Diquat	Analytical Method: EPA 549.2			Preparation Method: EPA 549.2			
Diquat	0.30	<0.30	ug/L	20	Below	20	Below
552.2 Haloacetic Acids	Analytical Method: EPA 552.2			Preparation Method: EPA 552.2			
Dibromoacetic Acid	0.37	<0.37	ug/L				
Dichloroacetic Acid	0.37	<0.37	ug/L				
Haloacetic Acids (Total)	0.37	<0.37	ug/L	60	Below	60	Below
Monobromoacetic Acid	0.37	<0.37	ug/L				
Monochloroacetic Acid	0.37	<0.37	ug/L				
Trichloroacetic Acid	0.37	<0.37	ug/L				
525.2 Base Neutral Extractable	Analytical Method: EPA 525.2			Preparation Method: EPA 525.2			
Benzo(a)pyrene	0.013	<0.013	ug/L	0.2	Below	0.2	Below
bis(2-Ethylhexyl)adipate	0.37	<0.37	ug/L	400	Below	400	Below
bis(2-Ethylhexyl)phthalate	0.54	<0.54	ug/L			6	Below
548.1 GCS Endothall	Analytical Method: EPA 548.1			Preparation Method: EPA 548.1			
Endothall	4.3	<4.3	ug/L	100	Below	100	Below
524.2 MSV	Analytical Method: EPA 524.2						
Benzene	0.25	<0.25	ug/L	5	Below	1	Below
Bromodichloromethane	0.25	<0.25	ug/L				
Bromoform	0.32	<0.32	ug/L				
Carbon tetrachloride	0.25	<0.25	ug/L	5	Below	5	Below
Chlorobenzene	0.25	<0.25	ug/L	100	Below	50	Below
Chloroform	0.25	<0.25	ug/L				
Dibromochloromethane	0.25	<0.25	ug/L				
1,2-Dichlorobenzene	0.25	<0.25	ug/L	600	Below	600	Below
1,4-Dichlorobenzene	0.25	<0.25	ug/L	75	Below	75	Below
1,2-Dichloroethane	0.25	<0.25	ug/L	5	Below	2	Below
1,1-Dichloroethane	0.25	<0.25	ug/L	7	Below	2	Below
cis-1,2-Dichloroethane	0.25	<0.25	ug/L	70	Below	70	Below
trans-1,2-Dichloroethane	0.25	<0.25	ug/L	100	Below	100	Below
1,2-Dichloropropane	0.25	<0.25	ug/L	5	Below	5	Below
Ethylbenzene	0.25	<0.25	ug/L	700	Below	700	Below
Methylene Chloride	0.44	<0.44	ug/L	5	Below	3	Below
Methyl-tert-butyl ether	0.25	<0.25	ug/L			70	Below
Naphthalene	0.25	<0.25	ug/L			300	Below
Styrene	0.25	<0.25	ug/L	100	Below	100	Below
1,1,2,2-Tetrachloroethane	0.25	<0.25	ug/L			1	Below
Tetrachloroethene	0.25	<0.25	ug/L	5	Below	1	Below
Toluene	0.25	<0.25	ug/L	1000	Below	1000	Below
Total Trihalomethanes (Calc.)	0.32	<0.32	ug/L	80	Below	10	Below
1,2,4-Trichlorobenzene	0.41	<0.41	ug/L	70	Below	9	Below
1,1,1-Trichloroethane	0.25	<0.25	ug/L	200	Below	30	Below
1,1,2-Trichloroethane	0.25	<0.25	ug/L	5	Below	3	Below
Trichloroethene	0.25	<0.25	ug/L	5	Below	1	Below
Vinyl chloride	0.39	<0.39	ug/L	2	Below	2	Below
Xylene (Total)	0.25	<0.25	ug/L	10000	Below	1000	Below
900.0 Gross Alpha/Beta	Analytical Method: EPA 900.0						
Gross Alpha	1.68	1.68U	pCi/L				

04/14/2017 16:08:51

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL
 N.M. - Indicates that the compound was not measured.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
 MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A
 State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;
 CO-IL100213; MI-9988

Maria Mozden
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT



Sample Results

Pace Analytical Services, Inc.
 8 East Tower Circle
 Ormond Beach, FL 32174
 (386) 672-5668

Client: Culligan International

Project ID: 1705451

Client ID: 1705451

Lab ID: 35303238001

Received: 03/29/2017 17:00

Pace Project No.: 35303238

Collected: 03/29/2017 17:00

Matrix: Drinking Water

Parameters	Report Limit	Results	Units	FDA Limit	Above/Below Limit	IBWA Limit	Above/Below Limit
903.1 Radium 226	Analytical Method: EPA 903.1						
Radium-226	0.661	0.661U	pCi/L				
904.0 Radium 228	Analytical Method: EPA 904.0						
Radium-228	0.660	0.660U	pCi/L				
300.1 Oxihalide IC Anions 14d	Analytical Method: EPA 300.1						
Chlorite	1.3	<1.3	ug/L	1000	Below	1000	Below
335.4 Cyanide, Total	Analytical Method: EPA 335.4						
Cyanide	0.0050	<0.0050	mg/L	0.1	Below	0.1	Below
353.2 Nitrogen, NO2/NO3 unpres	Analytical Method: EPA 353.2						
Nitrogen, Nitrate	0.025	0.094	mg/L				
Nitrogen, Nitrite	0.025	<0.025	mg/L				
Nitrogen, NO2 plus NO3	0.025	0.094	mg/L	10	Below	10	Below
420.4 Phenolics, Total Low Lvl	Analytical Method: EPA 420.4						
Phenolics, Total Recoverable LL	0.00060	<0.00060	mg/L	0.001	Below	0.001	Below

04/14/2017 16:08:51

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;

CO-IL100213; MI-9988

Maria Mozden
 Analytical Lab Manager

IBWA STANDARD OF QUALITY REPORT



Definitions/Qualifiers

Pace Analytical Services, Inc.
8 East Tower Circle
Ormond Beach, FL 32174
(386) 672-5668

Pace Project No.: 35303238

DEFINITIONS

- DF Dilution Factor
- J Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.
- U Indicates the compound was analyzed for, but not detected.
- MDL Adjusted Method Detection Limit
- PQL Practical Quantitation Limit
- ND Not Detected at or above adjusted reporting limit.

BATCH QUALIFIERS

Batch: GCSV 22279

- [1] A matrix spike/matrix spike duplicate was not performed for this batch due to insufficient sample volume.

ANALYTE QUALIFIERS

- 1p The internal standard response is below criteria. Sample is BDL so results are unaffected.
- CU The continuing calibration for this compound is outside of Pace Analytical acceptance limits. Analyte presence below reporting limits in associated samples.
- L1 Analyte recovery in the laboratory control sample (LCS) was above QC limits. Results for this analyte in associated samples may be biased high.

04/14/2017 16:08:51

page 6 of 8

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

NELAP Certifications: IL-100213; PA-68-04623; NY-11756; TX-TX269-2007A

State Certifications: IL-IDPH-17598; CA-2958; MT-CERT0091; IA-369; VT-VT02199; WI-399016200;

CO-IL100213; MI-9988

Maria Mozdzen
Analytical Lab Manager

